



# Certificate of Compliance

Certificate Number: LR 30024-29

Revision: LR 30024-29

Date Issued: April 4, 1996

Issued To: Echo Electric Co., Ltd.  
18-4, Shimouma 1-chome  
Setagaya-ku, Tokyo  
Japan

The products listed below are eligible to bear the CSA Mark.

Note: The "NRTL/C" indicator appears adjacent to the CSA Mark.

Issued By: Brij P. Aggarwal, P. Eng.  
Vancouver, BC Canada

Signature

## CLASS

6225 01 - FUSEHOLDER ASSEMBLIES  
6225 81 - FUSEHOLDER ASSEMBLIES

## PRODUCTS

Fuseholder assembly, extractor type, intended for panel mounting, Models FH001ASF, FH001AF and FH032AF, rated 15 A, 250 V ac.

Note: These fuseholders are Certified as components for use with other Certified equipment where the suitability of the combination is determined by the Canadian Standards Association.

## APPLICABLE REQUIREMENTS

CSA Standard C22.2 No 30-M1987 - Fuseholder Assemblies  
ANSI/UL 512-1992, Tenth Edition - Fuseholder Assemblies

sj