



CSA INTERNATIONAL

Certificate of Compliance

Certificate: 1088089

Master Contract: 168560 (LR 30024)

Edition: 1

Date Issued: June 6, 2000

Issued to: **Echo Electric Company Limited**
621 Nagai Yatsushiro-Cho
Higashi Yatsushiro-Gun
Yamanashi-Ken
Japan 406-0823

The products listed below are eligible to bear the CSA Mark shown



Issued by: Mehrdad Sadeghieh, P. Eng.

Signature: _____

PRODUCTS

CLASS 6225 01 - FUSEHOLDER ASSEMBLIES

Fuseholder assemblies, extractor type, intended for panel mounting, Models FH043 and FH033, rated 10 A, 250 V ac.

Notes:

1. The fuseholders are certified for use only as component parts of equipment where the acceptability of the combination is determined by the CSA International.
2. The fuseholders are certified for use with 5.2 mm by 20 mm fuses only.

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No. 39-M1987 - Fuseholder Assemblies



CSA INTERNATIONAL

Supplement to Certificate of Compliance

Certificate: 1088089

Master Contract: 168560 (LR 30024)

Edition: 1

Issued to: Echo Electric Company Limited
621 Nagai Yatsushiro-Cho
Higashi Yatsushiro-Gun
Yamanashi-Ken
Japan 406-0823

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Issued By: Mehrdad Sadeghieh, P. Eng.

Signature:

Product Certification History

Edition	Date	Description
1	June 6, 2000	Original Certification. (Transferred from Report LR 30024-33 and updated to include alternative construction of clip spring to Model FH033. Description of Model FH033 was added to the report because it was missing)